

## Corrigendum

TENDER No. RCB/IBDC/ 04-01/ 02/NIT-14/2023-24

Name of Work -Supply, Installation, Testing and Commissioning (SITC) work of Ductable Air Conditioning Units for Indian Biological Data Center (IBDC) at OOC Building in NCR Biotech Science Cluster, Faridabad.

### Reply of Pre-Bid Meeting held on 18.04.2024 at 15.00Hrs at RCB

SI No	Agency	Agency Query	RCB Response to the query
1	Air View	Your duct-able ac unit is ref – R07/R-22 . your copper pipe will not used	If existing copper pipe will not be used or compatible, then the bidder shall replace the existing copper pipe at no additional cost to the RCB. Also, the bidder will be allowed to collect old copper pipe used against new copper pipe of same or higher standard. The quality and quality of the old & new copper pipe shall be verified by RCB designated engineer/division.
2	Air View	Blue Star are making duct-able ac unit use ref.-R410 Inverter duct able AC or non- Inverter duct able AC. Your copper pipe will not use your copper pipe will changed. Extra copper pipe Approx. 210 RMT.	As mentioned in the point no. 1
3	JAM Infosystems Private Limited	Clause No2 pre-qualification criteria- All kind to HVAC works with any government/private reputed entity of required value shall be considered.	No Change
4	JAM Infosystems Private Limited	Buy Back – Do we get an invoice from RCB against buyback items	The buyback item will not be consider under sell of item. Gate pass will be issued to take the material outside campus at bidder's transportation cost.
5	JAM Infosystems Private Limited	Manufacturers Authorization Letter shall be asked to ensure OEM's Authentication for the product supplied & services in future	Yes, the bidder shall enclosed the Manufacturers Authorization Letter for Authentication of the supplied equipment, availability of the genuine spare parts, and their services in future.

Note: The amount quoted against items under buy back will be adjusted into quoted <sup>price</sup> items of the new items. The price bid format may be considered.

Tender opening date may be extended for 10 days from date of approval of this corrigendum.