


Corrigendum

TENDER No. RCB/IBDC/ 04-01/ 03/NIT-02/2024-25

Name of Work -Supply, Installation, Testing and Commissioning (SITC) work of UPS system for server racks cooling units at Indian Biological Data Centre (IBDC) at NCR Biotech Science Cluster, Faridabad.

Reply of Pre-Bid Meeting held on 23.04.2024 at 14.00Hrs at RCB

SI No	Agency	Agency Query	RCB Response to the query
1.	General	General	Bidders shall attached the MAF on OEM letter head for their quoted equipment'
2.	General	General	Preferred UPS Make- APC, ABB, Delta, Eaton, Rittal, Emerson/Vertiv Preferred Batteries Make- Exide, Amara Raja, Rocket, SF
3.	MATA	As per govt. standard practice, only 3% of contract value is applicable towards performance security.Request you to change the performance security value 10% to 3% of the contract value.	The successful tenderer will have to deposit, within 10 days from issue of LOI/Work order, the performance security deposit amount of @ 5 % of Work order amount in the form of Demand Draft/ Banker's cheque/ BG of any scheduled bank drawn in favour of "Executive Director, Regional Centre for Biotechnology" payable at Faridabad, valid till 6 months beyond the date of the contract period 5 years including CAMC. However, after completion of 2 years' standard warranty if CAMC not awarded then PBG would be released.
4.	MATA	We request you to provide relaxation on EPF/ESI registration to MSME registered bidders having total nos. of employee less than 20. However, we shall submit an undertaking in this regard.	Accepted
5.	MATA	Please clarify the kind of Earthing for UPS and UPS DB connectivity shall be used, i.e. Chemical earthing, Elctrode Earthing, Water Pipe Earthing etc. Please clarify the same.will be in the scope of bidders.	Existing earthing may be used connectivity from the main earthing shall be under bidders scope.
6.	MATA	Two different values are mentioned for Solvency Certificate. (Refer Clause 10 (Page No. 15 of 39) Please clarify the same.	The value of Solvency certificate may be read as Rs. 37.5 Lac in technical bid pg-15 pf 39 as well in every page where solvency value is mentioned.
7.	MATA	Two different values are mentioned for Solvency	Please refer RCB response mentioned against Sr. no. 6.

Indeep *not a part* 

		Certificate. (Refer Clause 5 (Page 3 of 39). Please clarify the same which one we have to follow.	
8.	MATA	Two different periods are mentioned for Performance Bank Guarantee. (Refer Clause 12.0.1 (Page No. 11 of 39). Request you to clarify the same..	Please refer RCB response mentioned against Sr. no. 3.
9.	JAM Infosystems Private Limited	We need clarification for the below statement: - Two different values are mentioned for Solvency Certificate. (Refer Clause 10 (Page No. 15 of 39) Please clarify the same which one we must follow.	Please refer RCB response mentioned against Sr. no. 6
10.	JAM Infosystems Private Limited	We need clarification for the below statement: - As per any Govt. Department standard practice, Labour License is applicable to civil work, whereas said RFP has major activity of electrical job only. Request you to remove this clause.	Please refer RCB response mentioned against Sr. no. 4
11.	JAM Infosystems Private Limited	We need clarification for the below statement: - As per Ministry of Finance (Procurement Policy Division), Notification No. 9/4/2020-PPD Dated: 30.12.2021, Performance Security from existing 5-10% to 3% of the value of the contract. Request you to change the performance security value 10% to 3% of the contract value.	Please refer RCB response mentioned against Sr. no. 3
12.	JAM Infosystems Private Limited	We need clarification for the below statement: - Two different timelines are mentioned in the tender for Performance Bank Guarantee Period. (Refer Clause 12.0.1 (Page No. 11 of 39). Request you to clarify the same which one we must follow.	Please refer RCB response mentioned against Sr. no. 3
13.	JAM Infosystems	We need clarification for the below statement: - Two different values are	Please refer RCB response mentioned against Sr. no. 6

Arundh

nd 7/2021



	Private Limited	mentioned for Solvency Certificate. (Refer Clause 5 (Page 3 of 39). Please clarify the same which one we must follow.	
14.	JAM Infosystems Private Limited	We need clarification for the below statement: - What type of Earthing for UPS and UPS DB connectivity shall be used, i.e. Chemical earthing, Earthing with Earth Electrode, Earthing through Water Pipe etc. Please clarify the same.	Please refer RCB response mentioned against Sr. no. 5.
15.	JAM Infosystems Private Limited	Arrangement for raw supply connectivity for UPS system, which is not clarified in the RFP, please elaborate.	Existing Raw power distribution is available, it will be under bidders scope to lay down the cable for new UPS connectivity from existing DB.
16	JAM Infosystems Private Limited	As you are already aware that ongoing general election might affect the arrangement of documents from OEM and Bidders as well, we request you to please extend the tender due date upto two weeks from the date of pre-bid meeting 23.04.2024	Tender submission date would be extend for 10 days from the date release of response to the pre bid queries.

Deep

adn

#